

## Models:

M2K03: 1 Speed FAN, 2 COOL and 2 HEAT Controller, 365 day  
Battery Backed Time Clock

## M2K03

### Micro2000 Controller

## Specifications

### Power Supply

- Voltage: 240VAC ±10% @ 50/60Hz
- Power Consumption: 7VA max.

### Inputs

- 10kΩ Thermistor temperature sensor
- Digital Input for Switched contact

### Outputs




Relay # 1: Voltage free relay contacts:  
Normally Open 240VAC, 16A resistive  
240VAC, 6A inductive

Relay # 2, 3: Voltage free relay contacts:  
Normally Open 240VAC, 10A resistive  
240VAC, 6A inductive

Relay # 4, 5: Voltage free relay contacts:  
Normally Open 240VAC, 2A resistive  
240VAC, 0.5A inductive

### Connection Between Controller and Control Station

- 3 way connection via 2 core plus screen cable



### Control Station Terminal Identification

- IN 1 Temperature Sensor input
- IN 2 Digital Input for Switched Contact
- IN 3 Digital Input for Switched Contact
- +12V Power from Controller
- Comms Comms to Controller
- GND Ground from Controller

### Controller Terminal Identification

240 Volt Power connection to Control Unit:

- Earth
- N Neutral supply
- 240V~ Mains 240VAC Supply

### Output Relays

- NO Normally open contact
- COM Common contact

### Comms Terminals

- +12V Power to Control Station
- Comms Comms from Control Station
- GND Ground to Control Station

### Battery

Contains a lithium type battery, dispose of properly.

(In accordance with local regulations)

- Type CR-2032 Lithium Battery
- Nominal voltage 3 Volts
- Shelf life 5 years, dependent on ambient temperature

Caution: Risk of Explosion if battery is replaced by an incorrect type.

### Temperature Ratings

- Storage: 0 to 50°C non-condensing
- Operating: 0 to 40°C non-condensing
- Sensor Input: 5 to 35°C

### Application

The Innotech Micro2000 Series Controllers are designed to be used in commercial applications to provide complete control for air conditioning systems.

### Features

- LED Display of Temperature and Program functions
- Control Station fits standard electrical wall plates
- Four core screened cable simplifies connection between the control station and controller
- Adjustable Proportional Band, Dead Zone, Compressor Restart Time, After hours Timer and Setpoint Range
- Able to operate as 2 cool, 2 electric heating or as reverse cycle heating or cooling
- After Hours function
- 365 Day Battery Backed Real Time Clock
- Programmable Schedules, 2 schedules per day
- Programmable Holidays, 20 On/Off Dates
- Storage of Accumulated After Hours Run Time
- All adjustments from the control station

## Approvals

The Micro2000 series controllers conform to:

- Electromagnetic emission and immunity requirements according to standards EN55011 (CISPR11) and EN50082 for CE Marking and C-Tick Labelling.

## Installation

1. The Micro2000 should be mounted on DIN rail in cabinets approved for switchgear or industrial control equipment. It should be mounted in a dry and clean location, free of excess vibration. Maximum terminal cable entry is 1.5mm<sup>2</sup> wire.
2. Wire in accordance with INNOTECH connection diagrams and local bylaws or refer to your local distributor.
3. Connect the 240VAC supply to the correct terminals on the controller, observing the correct polarity of the connections. Connect the EARTH to the correct terminals on all units.
4. The maximum wire length between the control station and the controller should not exceed 50 metres. The wiring between these devices should not be run in parallel with conductors carrying high current.

**!** This product should only be installed by qualified personnel.

## Fault Representation

1. If the Control Station display reads "HELP", this is due to a communications error between the Controller and the Control Station. Check the interconnecting 2 core screened cable for continuity or short circuits. As a result of this failure the controller will shutdown after 1 minute.
2. If the Control Station reads "SEN FAIL", this is due to an open circuit room Temperature Detector. To test the detector, disconnect it from the room and connect it directly to the controller.

## Inputs

1. INPUT 1 Temperature Sensor Input: (Range 5 - 35°C.)  
This input is used to read the current temperature.
2. INPUT 2 - Selectable Dry Contact Digital Input:  
Using Parameter 14, Input 2 can be either be an AC Fault Input, a External Disable Input, or a Condenser Water Fault Input.

### AC Fault

If "AC" is selected in Parameter 14 and Input 2 is "ON" the Micro2000 will display "AC FAIL" and continue to operate in its current mode. After the fault is rectified, the display will revert back to its previous state.

### External Disable

If "DIS" is selected in Parameter 14 and Input 2 is "ON" the Micro2000 will shut down all outputs and display "OFF". After the disable input is removed, the Micro2000 will continue to operate in its previous state.

### Condenser Water Fault

If "Con" is selected in Parameter 14 and Input 2 is "ON" the Micro2000 will shut down all outputs except the Fan, display "Con FAIL". After the fault is rectified, the Micro2000 will continue to operate in its previous state.

3. INPUT 3 - Selectable Dry Contact Digital Input:  
Using Parameter 15, Input 3 can be either an External After Hours Input, or a Door Switch Input.

## External Afterhours

If "AH" is selected in Parameter 15, Input 3 is used as an external toggle After Hours switch. It operation is the same as the  button on the front panel. See Push buttons section for more information.

### Door Switch

If "Door" is selected in Parameter 15 and Input 3 is "ON" for the time set in Parameter 16 (Door Open Time), then the Micro2000 will display "Door" and will go into Standby Mode. In Standby mode the Dead Band is increased by the adjustable value in Parameter 17 (Door Reset Dead Band). If Parameter 17 reads 10°C, there is a 5°C dead band either side of the setpoint. However if Parameter 17 is set to 0 (Off) then the Micro2000 will shutdown all outputs. After the door is closed the Micro2000 will continue to operate in its previous state.

 All Digital Inputs have a 5 second delay before they are registered. Except the Condenser Water Fault which has a 20 second delay.

## Outputs

Relay #1	Fan (16A Relay. Common and Normally Open Contact)
Relay #2	Heat 1 (10A Relay. Common and Normally Open Contact)
Relay #3	Heat 2 (10A Relay. Common and Normally Open Contact)
Relay #4	Cool 2 (2A Relay. Common and Normally Open Contact)
Relay #5	Cool 1 (2A Relay. Common and Normally Open Contact)

## Push Buttons

The normal control button use is described below:

1.  The "Auto" button is used to enable or disable the programmed schedules. When the Auto "LED" is on the schedules are enabled, when it is off they are disabled.
2.  This button has three selectable modes of operation.

### Normal After Hours

If Parameter 6 (After Hours Adjustable) is set to "Off", pressing the  button will instruct the Controller to run for the time set in Parameter 5 (After Hours Run Time).

### Adjustable After Hours Run Time

When the button is pressed and Parameter 6 is set to "On", the controller will display the amount of time in hours it will run for. The user can adjust this time by using the  and  buttons. The Controller will run for the amount of time chosen after the  button is pressed again or a period of 5 seconds where no buttons are pressed.

### Manual Override

When Parameter 5 is set to "On", the  button can be used to change the current state of the controller. It can be used to override any programmed schedules. For example if the Controller has been turned on by a Schedule, the  button can be used to force the controller Off until the next scheduled "On" time. Similarly if the controller is Off, the  button can be used to force the controller On, until the next scheduled "Off" time.


 If the Schedules are disabled via the  button, the  button has a normal On/Off function.

3.  This button can be used to select either Vent mode (Fan only runs) or Condition Mode (Full control).
4.  By pressing this button the Current Time will be displayed for 10 seconds before returning to the default display. If pressed again then the Current Date will be displayed for 10 seconds.
5.  The Up and Down buttons can be used to change the current Setpoint.

## After Hours Run Time

To view the accumulative After Hours Run Time, press and hold the  and  buttons for 5 seconds. The displayed value is the total after hours run time up to the previous hour. A total of 9999 hours may be accumulated.

To reset the After Hours Run Timer, simply press and hold the  and  buttons until the display reverts to 00.

To exit the After Hours Mode, press and hold the  button for 5 seconds again. The display will revert back to the default display.

## Start Up Default Settings

The Micro2000 can be set to start in certain modes of operation. To set the start up defaults, adjust the controller to the desired settings and then press and hold the  and  buttons for 5 seconds. When the screen becomes blank, release the buttons and the new Start Up Defaults will be saved.

## Weekly And Holiday Schedules

### 1. Weekly Schedules:

The Weekly Schedules allows the user to enter up to two On/Off schedules per day. For example if a schedule was added for Day 1 (Monday) from 7:30 to 17:30, the controller would turn on at 7:30 and turn off at 17:30 on every Monday.

### 2. Holidays:

The Holiday Schedules allows the user to enter up to 20 Holidays schedules. When a Holiday schedule is active it will override the weekly schedules and force the controller off. For example: if a holiday schedule was added for the 23/04 to 25/04, the controller would turn off at midnight on the morning of the 23/04 and stay off until midnight on the evening of the 25/04. For a single day holiday, set the On and Off dates to the same value.

## Programming Schedules / Clock

The function of the buttons while in programming mode is shown below.

 Enter	 Back
 Delete	 Copy

1. To enter the CLOCK / SCHEDULE programming mode, press and hold the  Button for 5 seconds. When the screen becomes blank, stop holding down the button.

2. When you have entered the programming mode, "\_CLO" will be displayed.

Use the  and  buttons to select either:

"_CLO"	Clock	"_SCH"	Weekly Schedules
--------	-------	--------	------------------

"\_HOL" Holidays

To Select press the .

 To exit out of Schedules / Clock programming mode at any time, press and hold the  Button for 5 sec then release.

3. If "\_CLO" was selected, the Current Time will be displayed. Use the  and  buttons to adjust. The  button can be used to toggle between the Time, Date, Year, DL Start Date and DL Stop Date. The Daylight Saving Start and Stop date are only available if Parameter 13 (Daylight Saving Enable) is set to "On". Press the  button to select or  button to go back to mode selection.

4. If "\_SCH" was selected in step 2, you can now set / edit the weekly schedules. The display will initially show "Day1". Use the  and  arrows to select which Day you wish to view. Press the  button to select or  button to go back.

5. After you have selected the day, the display will initially show "SCH1". Use the  and  buttons to select which schedule you wish to view. Press the  button to accept or the  button to go back to Step 2.
6. After selection, you can now set the On and Off times for that Day and Schedule. Use the  and  buttons to set the time. Press the  button to accept or the  button to go back.
7. A Schedule can be deleted by pressing the  button when viewing the "On" time for the particular schedule you wish to delete.
8. A copy function is available to copy a previous days schedule (Sch1 or Sch2). This can be done by pressing the  button while viewing the "On" time for the Schedule you wish to set.
9. If "\_HOL" was selected in step 2, you can now set / edit the holiday schedules. The Display will initially show "HOL1" (Holiday Schedule 1). Use the  and  arrows to select which Holiday schedule you wish to view. Press the  button to accept or the  button to go back to Step 2.
10. After selection, you can now set the Off and On Dates for the Holiday schedule. Use the  and  arrows to set the date. Press the  button to accept or the  button to go back.
11. An individual Holiday Schedule can be deleted by pressing the  button when viewing the Off time for the particular Holiday you wish to delete. If you wish to delete all the holiday schedules, press and hold the  button until the display show DEL.

## Programming Your Controller

To enter into the programming mode, press and hold the  button and the  arrow for 5 seconds. When the screen becomes blank, release the buttons.

- When you have entered the programming mode, "P 00" will be displayed (P=Parameter, 00=Parameter 0).
- In the programming mode, the  and  buttons select which Parameter is to be edited. (From Parameter 00 to 16).
- When you have selected the correct Parameter, press the  button. The value of that Parameter may then be altered by pressing the  or  buttons. When you have adjusted the Parameter to the desired setting, press the  button to confirm the changes.
- After confirming the changes (above), you will be back at the Parameter selection stage once again. Select and change parameters until have adjusted all Parameters you require.
- To EXIT the programming mode and SAVE your new settings, press and hold the  button for 5 seconds. When the screen becomes blank, release the button.

## Important Notes For Programming

- If you do not save your alterations, by holding the  button for 5 seconds, the controller will revert to the last saved settings.
- If you are in the process of adjusting a Parameter (Using the  and  buttons), and do not press any buttons for 30 seconds, the controller will revert back to the Parameter selection screen. (Eg. P 00)
- If the Parameter selection screen (Eg. P 00) is left unaltered for 60 seconds, the controller will revert to the last saved setting, and exit the programming mode.

## Parameters

### Parameter 0: Sensor Calibration

The display will show the sensor temperature. To offset the sensor temperature, adjust using the up and down buttons.

- The range of offset is  $\pm 10^{\circ}\text{C}$
- The factory default setting is  $0.0^{\circ}\text{C}$

### Parameter 1: Minimum Setpoint

The display will show the Minimum Setpoint to which the controller can be set.

- The range of Minimum Setpoint is 5 to  $35^{\circ}\text{C}$
- The factory default setting is  $15^{\circ}\text{C}$

### Parameter 2: Maximum Setpoint

The display will show the Maximum Setpoint to which the controller can be set.

- The range of Maximum Setpoint is 5 to  $35^{\circ}\text{C}$
- The factory default setting is  $30^{\circ}\text{C}$

### Parameter 3: Dead Band

The display will show the Dead Band setting.

- The range of the Dead Band is 0 to  $10.0^{\circ}\text{C}$
- The factory default setting is  $0.5^{\circ}\text{C}$

### Parameter 4: Proportional Band

The display will show the Proportional Band Setting. A Proportional Band setting of  $2^{\circ}\text{C}$  will result in a differential of  $2^{\circ}\text{C}$  for heating and  $2^{\circ}\text{C}$  for cooling.

- The range of Proportional Band is 0 to  $10.0^{\circ}\text{C}$
- The factory default setting is  $1.0^{\circ}\text{C}$

### Parameter 5: After Hours Timer

The display will show the After Hours Time. This is the period the unit will run for if an after hours pulse is received.

- The range of the After Hours Time is 1 to 24 hours to 'On'
- The factory default setting is 2 hours

### Parameter 6: After Hours Adjustable

The display will show the After Hours Adjustable setting.

- On: After hours timer will be adjustable
- Off: After hours timer will use the value in Parameter 5
- The factory default setting is Off

### Parameter 7: Fan Run On Time

The display will show the Fan Run On Time. This is the period the fan will run for if it is operating in heating and the controller is turned off. This is to remove any residual heat where electric heating is used.

- The range of the Run On Time is 0 to 500 seconds
- The factory default setting is 30 seconds

### Parameter 8: Compressor Minimum Off Time

The display will show the Compressor Minimum Off Time.

This is the period the compressor must remain off before it can restart.

- The range of the Off Time is 0 to 99 minutes
- The factory default setting is 4 minutes

### Parameter 9: EDH / REV

The display will show either EDH or REV to select which mode the controller will operate.

- Electric Heat mode (EDH): the heat and cool relays operate independently of each other.
- Reverse Cycle mode (REV): the cool relay controls the compressor in both cooling and heating operations. The heat relay operates the reversing valve.
- The factory default setting is EDH.

### Parameter 10: HEA / COOL

The Display will show either HEA or COOL to select if the reversing valve is energised for cooling or energised for heating.

- COOL: the heat relay will close during cooling
- HEA: the heat relay will close during heating
- The factory default setting is HEA

 This parameter is only effective if Parameter 9 is set for Reverse Cycle Operation.

### Parameter 11: Fan Cycle

The Display will show either On or Off to select continuous fan operation or fan cycles with heating.

- On: Fan cycles with heating
- Off: Fan runs continuously
- The factory default setting is Off

### Parameter 12: Setpoint Display Only

The display will show either On or Off.

- On: The setpoint is displayed
- Off: The current temperature is displayed
- The factory default setting is Off

### Parameter 13: Daylight Saving Enable

The display will show either On or Off.

- On: Daylight Saving is active
- Off: Daylight Saving is not active
- The factory default setting is Off

### Parameter 14: Input 2 Function

The display will show the current function of input 2.

- AC: AC Fault input
- DIS: External Disable input
- CON: Condenser Water Fault input
- The factory default setting is AC

### Parameter 15: Input 3 Function

The display will show the current function of input 3.

- AH: External After Hours input
- Door: Door Switch input
- The factory default setting is AH

### Parameter 16: Door Open Time

The display will show the Door Open Time.

This is the period the Door must be open before it is registered.

- The range of the Run On Time is 0 to 500 seconds
- The factory default setting is 30

### Parameter 17: Door Reset Dead Band

The display will show the Door Reset Dead Band Setting.


- The range of the Dead Band is OFF to  $10.0^{\circ}\text{C}$
- See section 'Inputs' for more information
- The factory default setting is OFF

**CAUTION**

The following describes potentially hazardous situations which, if not avoided, could result in death, serious or minor injury, or property damage.


1. Never touch the I/O terminals while power is being supplied.
2. Never attempt to disassemble the unit while power is being supplied.
3. Emergency stop circuits, limit circuits, interlock circuits and similar safety measures must be provided.
4. The Micro2000 outputs may remain On or Off due to burning or deposition of the output relays. External safety measures must be provided for such problems to ensure safety in the system.
5. Follow Innotech wiring diagrams and the installation / wiring instructions contained in this Datasheet.

## STANDARD CONNECTION CONTROL STATION




## ELECTRIC HEAT CONNECTION

### CONTROLLER



## REVERSE CYCLE CONNECTION

### CONTROLLER



**INNOTECH®**

Australian Owned, Designed & Manufactured  
 by Mass Electronics Brisbane

**Phone:** +61 7 3421 9100   **Fax:** +61 7 3421 9101  
**Email:** [sales@innotech.com.au](mailto:sales@innotech.com.au)   [www.innotech.com.au](http://www.innotech.com.au)

YOUR DISTRIBUTOR