

MS5-03 USER INSTRUCTIONS



The  button will switch the unit on or off. The display shows the sensed temperature until either of the  or  buttons are depressed. The set point will be displayed and continuing to press either the  or  buttons will increase or decrease the set point. If the  or  buttons have not been depressed for 5 seconds the display will revert to the sensed temperature.

*Note the range of this adjustment can be restricted.

The  button when pressed, will display the time in which the unit will change state ie if the unit is off, the unit will display the time in which the unit will turn on, and if the unit is on, it will display the time in which it will turn off. Continuing to press the button will increase this time by 10 minutes until it reaches 24 hours when it will rollover and display the minimum time adjustment. The time is adjustable from 10 minutes to 24 hours, if left for 5 seconds the display will revert to displaying the sensed temperature.

=INNOTECH=
CONTROL SYSTEMS

Designed & Manufactured in Australia
by Mass Electronics Brisbane
Ph 07 38411388 Fax 07 38411644

TITLE	MS5-03 USER INSTRUCTIONS	
MODEL NO	MICROCONTROLLER	
DATE	04-02-04	
DRAWN	AD	REV NO: A
APPROVED		